

From: [Programme Officer](#)
To: [Joanne Machol](#); [Diane Neville](#)
Subject: FW: Your ref: sub22HEDDPD Contact (M Haworth) Our ref: 3245
Date: 19 September 2017 12:26:05

From: [REDACTED]
Sent: 19 September 2017 12:08
To: Programme Officer
Subject: Your ref: sub22HEDDPD Contact (M Haworth) Our ref: 3245

Dear Sir/Madam,

HED DPD Submission Stage

We have considered the potential development sites within our Network Distribution Area and conclude that they could have an impact on our infrastructure. With the information supplied, it is not possible to determine the exact impact on our assets. As each development takes place, they will be reviewed during the usual planning application process.

The applicant should be advised that great care should be taken at all times to protect both the electrical apparatus and any personnel working in its vicinity.

The applicant should also be referred to two relevant documents produced by the Health and Safety Executive, which are available from The Stationery Office Publications Centre and The Stationery Office Bookshops, and advised to follow the guidance given.

The documents are as follows:-
HS(G)47 – Avoiding danger from underground services.
GS6 – Avoidance of danger from overhead electric lines.

The applicant should also be advised that, should there be a requirement to divert the apparatus because of the proposed works, the cost of such a diversion would usually be borne by the applicant. The applicant should be aware of our requirements for access to inspect, maintain, adjust, repair, or alter any of our distribution equipment. This includes carrying out works incidental to any of these purposes and this could require works at any time of day or night. Our Electricity Services Desk (Tel No. [REDACTED]) will advise on any issues regarding diversions or modifications.

Yours sincerely,

[REDACTED]
Commercial Manager
Electricity North West
Whitebirk Depot
Whitebirk Drive
Blackburn
BB1 3HT

**THINK BEFORE YOU
PRINT**=====

The information contained in this email is intended only for the individual to whom it is addressed. It may contain legally privileged or confidential information or otherwise be exempt from disclosure. If you have received this message in error or there are any problems, please notify the sender immediately and delete the message from your computer. YOU MUST NOT use, disclose, copy or alter this message for any unauthorized purpose. Neither Electricity North West Limited nor any of its subsidiaries will be liable for any direct, special, indirect or consequential damages as a result of any virus being passed on, or arising from the alteration of the contents of this message by a third party.

Electricity North West Limited
304 Bridgewater Place, Birchwood Park
Warrington WA3 6XG, Registered in England and Wales
Registration No 02366949
=====